

NFRC Attachment Product Certification Authorization Report



Issued By: National Accreditation And Management Institute
For: Erickson International LLC
 3135 Marco Street
 Las Vegas, NV 89115

Product Series: SKY 10	Type: Film	CPD Number: ERI-M-017
Tint: OT (Other)	Film Location: Interior	
Simulation Lab: SWWW	Simulation Date: 11/12/2014	Simulation Report Num: ERI14001R-RQ
Initial Certification Date: 12/11/2014	Re-Certification Date:	Report Date: 11/12/2014
Expiration Date: 11/12/2018	Print Date: 12/11/2014	

Default Operator Type	Default Glazing Reference	SHGC w/Film	VT w/Film	U-Factor
Fixed	3 mm (1/8in.) clear	0.16	0.05	0.99
Fixed	3 mm (1/8in.) clear 3 mm (1/8in.) clear	0.24	0.05	0.67
Window Wall	6 mm (1/4in.) clear	0.19	0.06	0.93
Window Wall	6 mm (1/4in.) grey	0.24	0.03	0.93
Window Wall	6 mm (1/4in.) clear 6 mm (1/4in.) clear	0.29	0.05	0.56
Window Wall	6 mm (1/4in.) grey 6 mm (1/4in.) clear	0.23	0.03	0.56

Comments:

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA Signature:
