

# NFRC Attachment Product Certification Authorization Report



**Issued By:** National Accreditation And Management Institute  
**For:** Erickson International LLC  
3135 Marco Street  
Las Vegas, NV 89115

**Product Series:** DAYDREAM 15  
**Tint:** OT (Other)  
**Simulation Lab:** SWES  
**Initial Certification Date:** 09/24/2019  
**Expiration Date:** 08/29/2023

**Type:** Film  
**Film Location:** Interior  
**Simulation Date:** 08/29/2018  
**Re-Certification Date:**  
**Print Date:** 09/24/2019

**CPD Number:** ERI-M-002  
**Simulation Report Num:** ERI19001-002-QQ  
**Report Date:** 08/29/2018

Default Operator Type	Default Glazing Reference	SHGC w/Film	VT w/Film	U-Factor
Fixed	3 mm (1/8in.) clear	0.25	0.13	1.00
Fixed	3 mm (1/8in.) clear 3 mm (1/8in.) clear	0.33	0.13	0.67
Window Wall	6 mm (1/4in.) clear	0.28	0.14	0.95
Window Wall	6 mm (1/4in.) grey	0.29	0.07	0.95
Window Wall	6 mm (1/4in.) clear 6 mm (1/4in.) clear	0.37	0.13	0.57
Window Wall	6 mm (1/4in.) grey 6 mm (1/4in.) clear	0.27	0.06	0.57

## Comments:

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA Signature:

A handwritten signature in black ink, appearing to be 'S. D.', is written over a horizontal line that serves as a signature line.