NFRC Attachment Product Certification Authorization Report

Issued By:National Accreditation And Management InstituteFor:Erickson International LLC3135 Marco StreetLas Vegas, NV 89115



Product Series: DHR 75 Tint: CL (Clear) Simulation Lab: SWES Initial Certification Date: 09/24/2019 Expiration Date: 08/29/2023

Type:FilmFilm Location:InteriorSimulation Date:08/29/2018Re-Certification Date:9/24/2019Print Date:09/24/2019

CPD Number: ERI-M-004

Simulation Report Num: ERI19001-004-QQ Report Date: 08/29/2018

Default Operator Type	Default Glazing Reference	SHGC w/Film	VT w/Film	U-Factor
Fixed	3 mm (1/8in.) clear	0.44	0.59	1.01
Fixed	3 mm (1/8in.) clear 3 mm (1/8in.) clear	0.45	0.54	0.67
Window Wall	6 mm (1/4in.) clear	0.47	0.63	0.95
Window Wall	6 mm (1/4in.) grey	0.38	0.32	0.95
Window Wall	6 mm (1/4in.) clear 6 mm (1/4in.) clear	0.49	0.56	0.57
Window Wall	6 mm (1/4in.) grey 6 mm (1/4in.) clear	0.33	0.28	0.57

Comments:

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA Signature: