

# NFRC Attachment Product Certification Authorization Report



**Issued By:** National Accreditation And Management Institute  
**For:** Erickson International LLC  
3135 Marco Street  
Las Vegas, NV 89115

**Product Series:** DIMENSION X  
**Tint:** CL (Clear)  
**Simulation Lab:** SWES  
**Initial Certification Date:** 09/24/2019  
**Expiration Date:** 08/29/2023

**Type:** Film  
**Film Location:** Interior  
**Simulation Date:** 08/29/2018  
**Re-Certification Date:**  
**Print Date:** 09/24/2019

**CPD Number:** ERI-M-005  
**Simulation Report Num:** ERI19001-005-QQ  
**Report Date:** 08/29/2018

Default Operator Type	Default Glazing Reference	SHGC w/Film	VT w/Film	U-Factor
Fixed	3 mm (1/8in.) clear	0.39	0.57	1.04
Fixed	3 mm (1/8in.) clear 3 mm (1/8in.) clear	0.42	0.52	0.69
Window Wall	6 mm (1/4in.) clear	0.42	0.60	0.99
Window Wall	6 mm (1/4in.) grey	0.37	0.30	0.99
Window Wall	6 mm (1/4in.) clear 6 mm (1/4in.) clear	0.46	0.53	0.59
Window Wall	6 mm (1/4in.) grey 6 mm (1/4in.) clear	0.32	0.27	0.59

## Comments:

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA Signature:

A handwritten signature in black ink, appearing to be 'Shi', is written over a horizontal line that serves as a signature line.