NFRC Attachment Product Certification Authorization Report

Issued By: National Accreditation And Management Institute

For: Erickson International LLC

3135 Marco Street Las Vegas, NV 89115



Report Date: 08/29/2018

Product Series: MOONLIGHT05 Type: Film CPD Number: ERI-M-008

Tint: OT (Other) Film Location: Interior

Simulation Lab: SWES Simulation Date: 08/29/2018 Simulation Report Num: ERI19001-008-QQ

Initial Certification Date: 09/24/2019 Re-Certification Date:

Expiration Date: 08/29/2023 **Print Date:** 09/24/2019

Default Operator Type	Default Glazing Reference	SHGC w/Film	VT w/Film	U-Factor
Fixed	3 mm (1/8in.) clear	0.31	0.05	1.02
Fixed	3 mm (1/8in.) clear 3 mm (1/8in.) clear	0.41	0.04	0.68
Window Wall	6 mm (1/4in.) clear	0.34	0.05	0.97
Window Wall	6 mm (1/4in.) grey	0.31	0.03	0.97
Window Wall	6 mm (1/4in.) clear 6 mm (1/4in.) clear	0.44	0.05	0.58
Window Wall	6 mm (1/4in.) grey 6 mm (1/4in.) clear	0.31	0.02	0.58

Comments:

I hereby certify that all requirements for NFRC Certification	Authorization have been met and that the above information	n is true and correct, to the best of my knowledge

Authorized IA Signature:

