

# NFRC Attachment Product Certification Authorization Report



**Issued By:** National Accreditation And Management Institute  
**For:** Erickson International LLC  
3135 Marco Street  
Las Vegas, NV 89115

**Product Series:** Twilight10 (int)  
**Tint:** OT (Other)  
**Simulation Lab:** SWWW  
**Initial Certification Date:** 07/25/2023  
**Expiration Date:** 06/28/2028

**Type:** Film  
**Film Location:** Interior  
**Simulation Date:** 06/28/2023  
**Re-Certification Date:**  
**Print Date:** 07/25/2023

**CPD Number:** ERI-M-032  
**Simulation Report Num:** ERI23001-RL  
**Report Date:** 06/28/2023

Default Operator Type	Default Glazing Reference	SHGC w/Film	VT w/Film	U-Factor
Fixed	3 mm (1/8in.) clear	0.25	0.07	1.03
Fixed	3 mm (1/8in.) clear 3 mm (1/8in.) clear	0.34	0.06	0.68
Window Wall	6 mm (1/4in.) clear	0.28	0.07	0.97
Window Wall	6 mm (1/4in.) grey	0.29	0.04	0.98
Window Wall	6 mm (1/4in.) clear 6 mm (1/4in.) clear	0.39	0.07	0.58
Window Wall	6 mm (1/4in.) grey 6 mm (1/4in.) clear	0.43	0.03	0.58

## Comments:

Appearance is: Charcoal

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA Signature:

A handwritten signature in black ink, appearing to be 'S.M.', is written over a horizontal line that serves as a signature line.