NFRC Attachment Product Certification Authorization Report

Issued By: National Accreditation And Management Institute

For: Erickson International LLC

3135 Marco Street Las Vegas, NV 89115



Report Date: 02/08/2024

Product Series:Dimension X (int)Type: FilmCPD Number: ERI-M-005

Tint: CL (Clear) Film Location: Interior

Simulation Lab: SWWW Simulation Date: 02/08/2024 Simulation Report Num: ERI24001-RL

Initial Certification Date: 02/28/2024 **Re-Certification Date:**

Default Operator Type	Default Glazing Reference	SHGC w/Film	VT w/Film	U-Factor
Fixed	3 mm (1/8in.) clear	0.33	0.50	0.98
Fixed	3 mm (1/8in.) clear 3 mm (1/8in.) clear	0.38	0.45	0.66
Window Wall	6 mm (1/4in.) clear	0.37	0.53	0.92
Window Wall	6 mm (1/4in.) grey	0.33	0.27	0.92
Window Wall	6 mm (1/4in.) clear 6 mm (1/4in.) clear	0.43	0.47	0.57
Window Wall	6 mm (1/4in.) grey 6 mm (1/4in.) clear	0.30	0.24	0.57

Comments:

I hereby certify that all requirements for NFRC Certific	cation Authorization have been met and tha	it the above information is true and c	orrect, to the best of m	ıy knowledge

Authorized IA Signature: