

NFRC Attachment Product Certification Authorization Report



Issued By: National Accreditation And Management Institute
For: Erickson International LLC
3135 Marco Street
Las Vegas, NV 89115

Product Series: Moonlight 10 (int) **Type:** Film **CPD Number:** ERI-M-009
Tint: BK (Black) **Film Location:** Interior
Simulation Lab: SWWW **Simulation Date:** 02/08/2024 **Simulation Report Num:** ERI24001-RL
Initial Certification Date: 02/28/2024 **Re-Certification Date:** **Report Date:** 02/08/2024
Expiration Date: 02/08/2029 **Print Date:** 02/28/2024

Default Operator Type	Default Glazing Reference	SHGC w/Film	VT w/Film	U-Factor
Fixed	3 mm (1/8in.) clear	0.33	0.09	1.04
Fixed	3 mm (1/8in.) clear 3 mm (1/8in.) clear	0.42	0.08	0.69
Window Wall	6 mm (1/4in.) clear	0.36	0.09	0.99
Window Wall	6 mm (1/4in.) grey	0.32	0.05	0.99
Window Wall	6 mm (1/4in.) clear 6 mm (1/4in.) clear	0.45	0.08	0.59
Window Wall	6 mm (1/4in.) grey 6 mm (1/4in.) clear	0.32	0.04	0.59

Comments:

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA Signature:

A handwritten signature in black ink, appearing to be 'Shirley', is written over a horizontal line that serves as a signature line.