## **NFRC Attachment Product Certification Authorization Report**

**Issued By:** National Accreditation And Management Institute

For: Erickson International LLC

3135 Marco Street Las Vegas, NV 89115



Report Date: 02/08/2024

Product Series: Nature 30 (int)

Type: Film

CPD Number: ERI-M-012

Tint: SR (Silver) Film Location: Interior

Simulation Lab: SWWW Simulation Date: 02/08/2024 Simulation Report Num: ERI24001-RL

**Initial Certification Date:** 02/28/2024 **Re-Certification Date:** 

**Expiration Date:** 02/08/2029 **Print Date:** 02/28/2024

Default Operator Type	Default Glazing Reference	SHGC w/Film	VT w/Film	U-Factor
Fixed	3 mm (1/8in.) clear	0.36	0.26	1.06
Fixed	3 mm (1/8in.) clear 3 mm (1/8in.) clear	0.43	0.24	0.69
Window Wall	6 mm (1/4in.) clear	0.39	0.27	1.01
Window Wall	6 mm (1/4in.) grey	0.35	0.14	1.01
Window Wall	6 mm (1/4in.) clear 6 mm (1/4in.) clear	0.46	0.25	0.59
Window Wall	6 mm (1/4in.) grey 6 mm (1/4in.) clear	0.32	0.12	0.59

## **Comments:**

I hereby certify that all requirements for NFRC Certification	Authorization have been met and that the	e above information is true and correct,	to the best of my knowledge

Authorized IA Signature: