

NFRC Attachment Product Certification Authorization Report



Issued By: National Accreditation And Management Institute
For: Erickson International LLC
 3135 Marco Street
 Las Vegas, NV 89115

Product Series: Reflection 35 (int)	Type: Film	CPD Number: ERI-M-015
Tint: BL (Blue)	Film Location: Interior	
Simulation Lab: SWWW	Simulation Date: 02/08/2024	Simulation Report Num: ERI24001-RL
Initial Certification Date: 02/28/2024	Re-Certification Date:	Report Date: 02/08/2024
Expiration Date: 02/08/2029	Print Date: 02/28/2024	

Default Operator Type	Default Glazing Reference	SHGC w/Film	VT w/Film	U-Factor
Fixed	3 mm (1/8in.) clear	0.32	0.30	1.00
Fixed	3 mm (1/8in.) clear 3 mm (1/8in.) clear	0.37	0.28	0.67
Window Wall	6 mm (1/4in.) clear	0.35	0.32	0.94
Window Wall	6 mm (1/4in.) grey	0.32	0.16	0.94
Window Wall	6 mm (1/4in.) clear 6 mm (1/4in.) clear	0.40	0.29	0.58
Window Wall	6 mm (1/4in.) grey 6 mm (1/4in.) clear	0.29	0.14	0.58

Comments:

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA Signature:
