

NFRC Attachment Product Certification Authorization Report



Issued By: National Accreditation And Management Institute
For: Erickson International LLC
3135 Marco Street
Las Vegas, NV 89115

Product Series: Sky 10 (int)
Tint: BK (Black)
Simulation Lab: SWWW
Initial Certification Date: 02/28/2024
Expiration Date: 02/08/2029

Type: Film
Film Location: Interior
Simulation Date: 02/08/2024
Re-Certification Date:
Print Date: 02/28/2024

CPD Number: ERI-M-017
Simulation Report Num: ERI24001-RL
Report Date: 02/08/2024

Default Operator Type	Default Glazing Reference	SHGC w/Film	VT w/Film	U-Factor
Fixed	3 mm (1/8in.) clear	0.16	0.06	0.99
Fixed	3 mm (1/8in.) clear 3 mm (1/8in.) clear	0.23	0.05	0.67
Window Wall	6 mm (1/4in.) clear	0.19	0.06	0.94
Window Wall	6 mm (1/4in.) grey	0.25	0.03	0.94
Window Wall	6 mm (1/4in.) clear 6 mm (1/4in.) clear	0.28	0.06	0.57
Window Wall	6 mm (1/4in.) grey 6 mm (1/4in.) clear	0.23	0.03	0.57

Comments:

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA Signature:

A handwritten signature in black ink, appearing to be 'S.M.', is written over a solid black horizontal line.