

# NFRC Attachment Product Certification Authorization Report



**Issued By:** National Accreditation And Management Institute  
**For:** Erickson International LLC  
3135 Marco Street  
Las Vegas, NV 89115

**Product Series:** Sky 20 (int)  
**Tint:** BK (Black)  
**Simulation Lab:** SWWW  
**Initial Certification Date:** 02/28/2024  
**Expiration Date:** 02/08/2029

**Type:** Film  
**Film Location:** Interior  
**Simulation Date:** 02/08/2024  
**Re-Certification Date:**  
**Print Date:** 02/28/2024

**CPD Number:** ERI-M-018  
**Simulation Report Num:** ERI24001-RL  
**Report Date:** 02/08/2024

Default Operator Type	Default Glazing Reference	SHGC w/Film	VT w/Film	U-Factor
Fixed	3 mm (1/8in.) clear	0.26	0.16	1.01
Fixed	3 mm (1/8in.) clear 3 mm (1/8in.) clear	0.33	0.15	0.68
Window Wall	6 mm (1/4in.) clear	0.29	0.17	0.95
Window Wall	6 mm (1/4in.) grey	0.29	0.09	0.95
Window Wall	6 mm (1/4in.) clear 6 mm (1/4in.) clear	0.36	0.16	0.58
Window Wall	6 mm (1/4in.) grey 6 mm (1/4in.) clear	0.27	0.08	0.58

## Comments:

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA Signature:

A handwritten signature in black ink, appearing to be 'Shi', is written over a solid black horizontal line.