

NFRC Attachment Product Certification Authorization Report



Issued By: National Accreditation And Management Institute
For: Erickson International LLC
3135 Marco Street
Las Vegas, NV 89115

Product Series: Sky 40 (int)
Tint: BK (Black)
Simulation Lab: SWWW
Initial Certification Date: 02/28/2024
Expiration Date: 02/08/2029

Type: Film
Film Location: Interior
Simulation Date: 02/08/2024
Re-Certification Date:
Print Date: 02/28/2024

CPD Number: ERI-M-020
Simulation Report Num: ERI24001-RL
Report Date: 02/08/2024

Default Operator Type	Default Glazing Reference	SHGC w/Film	VT w/Film	U-Factor
Fixed	3 mm (1/8in.) clear	0.44	0.40	1.04
Fixed	3 mm (1/8in.) clear 3 mm (1/8in.) clear	0.47	0.37	0.69
Window Wall	6 mm (1/4in.) clear	0.47	0.43	0.99
Window Wall	6 mm (1/4in.) grey	0.39	0.21	0.99
Window Wall	6 mm (1/4in.) clear 6 mm (1/4in.) clear	0.50	0.38	0.59
Window Wall	6 mm (1/4in.) grey 6 mm (1/4in.) clear	0.34	0.19	0.59

Comments:

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA Signature:

A handwritten signature in black ink, appearing to be 'M. O.', is written over a horizontal line that serves as a signature line.