NFRC Attachment Product Certification Authorization Report

Issued By: National Accreditation And Management Institute

For: Erickson International LLC

3135 Marco Street Las Vegas, NV 89115



Report Date: 06/28/2023

Product Series: Aurora50 (int) Type: Film CPD Number: ERI-M-024

Tint: CL (Clear) Film Location: Interior

Simulation Lab: SWWW Simulation Date: 06/28/2023 Simulation Report Num: ERI23001-RL

Initial Certification Date: 07/25/2023 **Re-Certification Date:**

Default Operator Type	Default Glazing Reference	SHGC w/Film	VT w/Film	U-Factor
Fixed	3 mm (1/8in.) clear	0.34	0.41	1.05
Fixed	3 mm (1/8in.) clear 3 mm (1/8in.) clear	0.42	0.38	0.69
Window Wall	6 mm (1/4in.) clear	0.38	0.44	0.99
Window Wall	6 mm (1/4in.) grey	0.34	0.22	1.00
Window Wall	6 mm (1/4in.) clear 6 mm (1/4in.) clear	0.45	0.39	0.59
Window Wall	6 mm (1/4in.) grey 6 mm (1/4in.) clear	0.46	0.19	0.59

Comments:

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my k	inowledge
---	-----------

Authorized IA Signature: