

NFRC Attachment Product Certification Authorization Report



Issued By: National Accreditation And Management Institute
For: Erickson International LLC
3135 Marco Street
Las Vegas, NV 89115

Product Series: Firewall70 (int)
Tint: BL (Blue)
Simulation Lab: SWWW
Initial Certification Date: 07/25/2023
Expiration Date: 06/28/2028

Type: Film
Film Location: Interior
Simulation Date: 06/28/2023
Re-Certification Date:
Print Date: 07/25/2023

CPD Number: ERI-M-025
Simulation Report Num: ERI23001-RL
Report Date: 06/28/2023

Default Operator Type	Default Glazing Reference	SHGC w/Film	VT w/Film	U-Factor
Fixed	3 mm (1/8in.) clear	0.47	0.56	1.10
Fixed	3 mm (1/8in.) clear 3 mm (1/8in.) clear	0.52	0.50	0.71
Window Wall	6 mm (1/4in.) clear	0.50	0.59	1.04
Window Wall	6 mm (1/4in.) grey	0.41	0.30	1.04
Window Wall	6 mm (1/4in.) clear 6 mm (1/4in.) clear	0.54	0.53	0.60
Window Wall	6 mm (1/4in.) grey 6 mm (1/4in.) clear	0.51	0.26	0.60

Comments:

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA Signature:

A handwritten signature in black ink, appearing to be 'M.D.', is written over a horizontal line that serves as a signature line.